DEPARTMENT OF ENVIRONMENTAL PROTECTION

B

BACTERIOLOGICAL ANALYSIS REPORT - CONTAMINANT ID#3100

PWS ID #	Public Water System Name	Town/City	Laboratory Name & ID #
1191000	Monson Water & Sewer Dept.	Monson	Spectrum Analytical, Inc. M-MA138

		DEP Approved Sample Site											
Sample Type	Lab Sample ID #	Code #	Location	Collection Date	Collection Time	Analysis Date	TCM Code #	Tot Coliform/ 100ml**	FC/ECM Code #	Fecal - E.Coli/ 100ml**	Chlor. Residual	HPC/ ml	Sample Collected by:
RS	SA49096-01	001	Gate House	8/7/06	08:09	8/7/06	*303	0	*303				Tom Murphy
RS	SA49096-02	003	Middle School	8/7/06	08:13	8/7/06	*303	0	*303				Tom Murphy
RS	SA49096-03	009	MDC Meter Bld.	8/7/06	08:43	8/7/06	*303	0	*303				Tom Murphy
RS	SA49096-04	007	Fire Station	8/7/06	09:06	8/7/06	*303	0	*303				Tom Murphy
RW	SA49096-06		Bunyan Road Well	8/7/06	08:51	8/7/06	*303	0	*303				Tom Murphy
RW	SA49096-07		Palmer Road Well	8/7/06	08:57	8/7/06	*303	0	*303				Tom Murphy

SAMPLE TYPE KEY
RS- ROUTINE SAMPLE RO- ORIGINAL SITE REPEAT UR- UPSTREAM REPEAT DR- DOWNSTREAM REPEAT AR- ADD. REPEAT(DIST SYSTEM) RW- RAW WATER SS- SPECIAL PT- PLANT TAP SAMPLE

TOTAL COLIFORM METHOD(TCM) CODE #			
MF	3	0	3
MTF	3	0	5
P-A	3	0	7
ONPG	3	0	9
***	3	1	1

FECAL COLIFORM/ E. COLI METHOD (FC/ECM) CODE #			
EC	4	0	0
SWTR-MFC raw water	4	0	1
MMO-MUG	4	0	6
EC-MUG	4	0	8
NA-MUG	4	1	0

REMARKS: *303=EPA Method 1604: Total Coliforms and Escherichia coli in Water by Membrane Filtration Using a Simultaneous Detection Technique (MI Medium)

SUBCONTRACTED LAB (IF APPLICABLE):

ANALYZED BY: Spectrum Analytical, Inc. (LAB USE) DATE: 8/7/06

AUTHORIZED BY: (LAB USE) DATE: 8/14/06

* LAB ID# ASSIGNED BY STATE CERTIFICATION PROGRAM
** CAN BE EXPRESSED AS #/100ML, PRESENT(P), ABSENT(A), OR TOO NUMEROUS TO COUNT (TNTC)
*** COLISURE METHOD - THIS CAN DO TOTAL COLIFORM and E.COLI SIMULTANEOUSLY, HOWEVER THE SAMPLE MUST BE INCUBATED 28 TO 48 HOURS.

COPY 1: COPY TO DEP REGIONAL OFFICE; COPY 2: OWNER COPY; COPY 3: LAB COPY

cl\colifrm2.frm 10/25/96

RECEIVED AUG 2 - 2006