



Inorganic Contaminant Report

COPY

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: **1191000** City / Town: **MONSON**

PWS Name: **Monson Water & Sewer** PWS Class: COM NTNC TNC

DEP LOCATION (LOC) ID#	DEP Location Name	Sample Information <small>*Please note all samples are considered representative of finished water if there is no treatment applied</small>	Date Collected	Collected By
10003	Bethany Road Well	<input type="checkbox"/> (M)ultiple <input checked="" type="checkbox"/> (S)ingle <input type="checkbox"/> (R)aw <input checked="" type="checkbox"/> (F)inished	7/1/2014	C. Jalbert

Routine or Special Sample	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:	
		(1) Reason for Resubmission	(2) Collection Date of Original Sample
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction	

SAMPLE NOTES - (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert. #: **MA-100** Primary Lab Name: **Con-Test Analytical Lab** Subcontracted? (Y/N) **N**

Contaminant	Result (mg/L)	MCL (mg/L)	MDL (mg/L)	Lab Method	Date Analyzed	Analysis Lab MA Cert #	Analysis Lab Name	Lab Sample ID#
ANTIMONY		0.006						
ARSENIC		0.010						
BARIUM		2						
BERYLLIUM		0.004						
CADIUM		0.005						
CHROMIUM		0.1						
CYANIDE		0.2						
FLUORIDE ¹		4.0						
MERCURY ²		0.002						
NICKEL		0.1*						
SELENIUM		0.05						
SODIUM	70	20*	2.0	EPA 200.7	7/5/2014	MA-100	CONTEST LAB	14G0012-03
THALLIUM		0.002						

¹Fluoride also has a secondary MCL of 2.0 mg/L. Community water systems which exceed this limit must provide public notice pursuant to 310 CMR 22.16.
²Please note that if method 245.1 is used for mercury, only method revision 3.0 will be accepted by MA DEP.
 *No current MCL, however DEP Office of Research and Standards has established a guideline (ORSG) limit for this contaminant.

Was this Sample composited by the Lab?	COMPOSITE SAMPLE NOTES List the composited sources by DEP Source Code (XXXXXXX-XXX), up to five individual sources per sample.
Yes <input type="checkbox"/>	

LAB SAMPLE NOTES

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature: *[Signature]*
 Date: **7/23/14**

If not submitting these results electronically, mail TWO copies of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

DEP REVIEW STATUS (Initial & Date)	Review Comments	<input type="checkbox"/> WQTS Data Entered
<input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved		



Inorganic Contaminant Report

COPY IOC

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: **1191000** City / Town: **MONSON**
 PWS Name: **Monson Water & Sewer** PWS Class: COM NTNC TNC

DEP LOCATION (LOC) ID#	DEP Location Name	Sample information <small>*Please note all samples are considered representative of finished water if there is no treatment applied</small>	Date Collected	Collected By
10002	Palmer Road Well	<input type="checkbox"/> (M)ultiple <input type="checkbox"/> (R)aw <input checked="" type="checkbox"/> (S)ingle <input checked="" type="checkbox"/> (F)inished	7/1/2014	C. Jalbert
Routine or Special Sample	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:		
		(1) Reason for Resubmission	(2) Collection Date of Original Sample	
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction		
SAMPLE NOTES – (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).				

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert. #: **MA-100** Primary Lab Name: **Con-Test Analytical Lab** Subcontracted? (Y/N) **N**

Contaminant	Result (mg/L)	MCL (mg/L)	MDL (mg/L)	Lab Method	Date Analyzed	Analysis Lab MA Cert #	Analysis Lab Name	Lab Sample ID#
ANTIMONY		0.006						
ARSENIC		0.010						
BARIIUM		2						
BERYLLIUM		0.004						
CADMIUM		0.005						
CHROMIUM		0.1						
CYANIDE		0.2						
FLUORIDE ¹		4.0						
MERCURY ²		0.002						
NICKEL		0.1*						
SELENIUM		0.05						
SODIUM	52	20*	2.0	EPA 200.7	7/5/2014	MA-100	CONTEST LAB	14G0012-02
THALLIUM		0.002						

¹Fluoride also has a secondary MCL of 2.0 mg/L. Community water systems which exceed this limit must provide public notice pursuant to 310 CMR 22.16.

²Please note that if method 245.1 is used for mercury, only method revision 3.0 will be accepted by MA DEP.

*No current MCL, however DEP Office of Research and Standards has established a guideline (ORSG) limit for this contaminant.

Was this Sample composited by the Lab? Yes <input type="checkbox"/>	COMPOSITE SAMPLE NOTES List the composited sources by DEP Source Code (XXXXXXX-XXX), up to five individual sources per sample.
LAB SAMPLE NOTES	

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature:

Date: 7/23/14

If not submitting these results electronically, mail TWO copies of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

DEP REVIEW STATUS (Initial & Date) <input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved	Review Comments	<input type="checkbox"/> WQTS Data Entered
--	-----------------	--



Inorganic Contaminant Report

COPY

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: **1191000** City / Town: **MONSON**
 PWS Name: **Monson Water & Sewer** PWS Class: **COM** **NTNC** **TNC**

DEP LOCATION (LOC) ID#	DEP Location Name	Sample Information <small>*Please note all samples are considered representative of finished water if there is no treatment applied.</small>	Date Collected	Collected By
10009	Bunyan Wells Comb.	<input checked="" type="checkbox"/> (M)ultiple <input type="checkbox"/> (R)aw <input type="checkbox"/> (S)ingle <input checked="" type="checkbox"/> (F)inished	7/1/2014	C. Jalbert
Routine or Special Sample	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:		
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	(1) Reason for Resubmission <input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction	(2) Collection Date of Original Sample	
SAMPLE NOTES - (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).				

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert. #: **MA-100** Primary Lab Name: **Con-Test Analytical Lab** Subcontracted? (Y/N) **N**

Contaminant	Result (mg/L)	MCL (mg/L)	MDL (mg/L)	Lab Method	Date Analyzed	Analysis Lab MA Cert #	Analysis Lab Name	Lab Sample ID#
ANTIMONY		0.006						
ARSENIC		0.010						
BARIUM		2						
BERYLLIUM		0.004						
CADMIUM		0.005						
CHROMIUM		0.1						
CYANIDE		0.2						
FLUORIDE ¹		4.0						
MERCURY ²		0.002						
NICKEL		0.1*						
SELENIUM		0.05						
SODIUM	35	20*	2.0	EPA 200.7	7/5/2014	MA-100	CONTEST LAB	14G0012-01
THALLIUM		0.002						


¹Fluoride also has a secondary MCL of 2.0 mg/L. Community water systems which exceed this limit must provide public notice pursuant to 310 CMR 22.16.

²Please note that if method 245.1 is used for mercury, only method revision 3.0 will be accepted by MA DEP.

*No current MCL, however DEP Office of Research and Standards has established a guideline (ORSG) limit for this contaminant.

Was this Sample composited by the Lab? Yes <input type="checkbox"/>	COMPOSITE SAMPLE NOTES List the composited sources by DEP Source Code (XXXXXXX-XXX), up to five individual sources per sample.
LAB SAMPLE NOTES	

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature: 

Date: **7/23/14**

If not submitting these results electronically, mail TWO copies of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

DEP REVIEW STATUS (Initial & Date) <input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved	Review Comments	<input type="checkbox"/> WQTS Data Entered
--	-----------------	--