RECEIVED MAY 17 2006

MASSACHUSETTS DEP/DIVISION OF WATER SUPPLY **VOC**

VOLATILE ORGANIC CONTAMINANT REPORT

(FORM #7.3)

I. PWS INFORMATION

1. PWS ID#: 1 1 9 1 0 0 0 City/Town: Monson
3. PWS Name: Monson Water and Sewer Department 4. PWS Class (circle one): **COM**, NTNC, NC
5. DEP Source/Location ID: 1191000-10009 6. Sample Location: Bunyan Road Wells Combined 7. Date Collected: 5/2/2006 8. Collected by: Jalbert
9. Is the Source Treated? Yes 10. Was the Sample Collected After Treatment? Yes
11. Manifolded [X] If applicable, list the connected sources: Bunyan Road 06G & 07G
12. Routine [x] Special [ ] (explain below)

Notes:

II. LABORATORY ANALYTICAL INFORMATION:

Lab Name: STL WESTFIELD Lab Cert.#: MA-014
Subcontracted? (Y,N) N Lab Sample ID#: 360-3079-1
Sub. Lab Name: Sub. Lab Cert.#:
Composited [ ] If applicable, list the composited sources:

Notes:

Compound (Regulated)	Result µg/L	MCL µg/L	Detection Limit µg/L	Analytical Method	Date Analyzed
Benzene	ND	5.0	0.5	524.2	5/8/2006
Carbon Tetrachloride	ND	5.0	0.5	524.2	5/8/2006
1,1-Dichloroethylene	ND	7.0	0.5	524.2	5/8/2006
1,2-Dichloroethane	ND	5.0	0.5	524.2	5/8/2006
para-Dichlorobenzene	ND	5.0	0.5	524.2	5/8/2006
Trichloroethylene	ND	5.0	0.5	524.2	5/8/2006
1,1,1-Trichloroethane	ND	200.0	0.5	524.2	5/8/2006
Vinyl Chloride	ND	2.0	0.5	524.2	5/8/2006
Monochlorobenzene	ND	100.0	0.5	524.2	5/8/2006
o-Dichlorobenzene	ND	600.0	0.5	524.2	5/8/2006
trans-1,2-Dichloroethylene	ND	100.0	0.5	524.2	5/8/2006
cis-1,2-Dichloroethylene	ND	70.0	0.5	524.2	5/8/2006
1,2-Dichloropropane	ND	5.0	0.5	524.2	5/8/2006
Ethylbenzene	ND	700.0	0.5	524.2	5/8/2006
Styrene	ND	100.0	0.5	524.2	5/8/2006
Tetrachloroethylene	ND	5.0	0.5	524.2	5/8/2006
Toluene	ND	1000.0	0.5	524.2	5/8/2006
Xylenes (total)	ND	10000.0	1.0	524.2	5/8/2006
Dichloromethane	ND	5.0	0.5	524.2	5/8/2006
1,2,4-Trichlorobenzene	ND	70.0	0.5	524.2	5/8/2006
1,1,2-Trichloroethane	ND	5.0	0.5	524.2	5/8/2006
Methyl Tertiary Butyl Ether	ND	70.0	0.5	524.2	5/8/2006

RECEIVED MAY 1 7 2006

(FORM #7.3)

PWS ID No: 1191000-10009 Town: Monson

VOC

Compound (Unregulated)	Result µg/L	Detection Limit µg/L	Analytical Method	Date Analyzed
Chloroform	ND	0.5	524.2	5/8/2006
Bromodichloromethane	ND	0.5	524.2	5/8/2006
Chlorodibromomethane	ND	0.5	524.2	5/8/2006
Bromoform	ND	0.5	524.2	5/8/2006
m-Dichlorobenzene	ND	0.5	524.2	5/8/2006
Dibromomethane	ND	0.5	524.2	5/8/2006
1,1-Dichloropropene	ND	0.5	524.2	5/8/2006
1,1-Dichloroethane	ND	0.5	524.2	5/8/2006
1,1,2,2-Tetrachloroethane	ND	0.5	524.2	5/8/2006
1,3-Dichloropropane	ND	0.5	524.2	5/8/2006
Chloromethane	ND	0.5	524.2	5/8/2006
Bromomethane	ND	0.5	524.2	5/8/2006
1,2,3-Trichloropropane	ND	0.5	524.2	5/8/2006
1,1,1,2-Tetrachloroethane	ND	0.5	524.2	5/8/2006
Chloroethane	ND	0.5	524.2	5/8/2006
2,2-Dichloropropane	ND	0.5	524.2	5/8/2006
o-Chlorotoluene	ND	0.5	524.2	5/8/2006
p-Chlorotoluene	ND	0.5	524.2	5/8/2006
Bromobenzene	ND	0.5	524.2	5/8/2006
1,3-Dichloropropene	ND	0.5	524.2	5/8/2006
1,2,4-Trimethylbenzene	ND	0.5	524.2	5/8/2006
1,2,3-Trichlorobenzene	ND	0.5	524.2	5/8/2006
n-Propylbenzene	ND	0.5	524.2	5/8/2006
n-Butylbenzene	ND	0.5	524.2	5/8/2006
Naphthalene	ND	0.5	524.2	5/8/2006
Hexachlorobutadiene	ND	0.5	524.2	5/8/2006
1,3,5-Trimethylbenzene	ND	0.5	524.2	5/8/2006
p-Isopropyltoluene	ND	0.5	524.2	5/8/2006
Isopropylbenzene	ND	0.5	524.2	5/8/2006
Tert-butylbenzene	ND	0.5	524.2	5/8/2006

(FORM #7.3)

RECEIVED MAY 1 7 2006

PWS ID No: 1191000-10009

Town: Monson

VOC

Compound (Unregulated)	Result µg/L	Detection Limit µg/L	Analytical Method	Date Analyzed
Sec-butylbenzene	ND	0.5	524.2	5/8/2006
Fluorotrichloromethane	ND	0.5	524.2	5/8/2006
Dichlorodifluoromethane	ND	0.5	524.2	5/8/2006
Bromochloromethane	ND	0.5	524.2	5/8/2006

Surrogate Recoveries (As required by EPA methods 502.1 and 524.2)

Compound	% Recovered	QC Limits (%)
1,2 Dichloroethane-d4	111	70-130
4-Bromofluorobenzene	96	70-130

The QA/QC required matrix spike sample information is on file at our office.

Laboratory Director Signature and Date: C. Reynolds for S. Hartmann 5/16/06

Attention: Mail TWO copies of this report to your **DEP Regional Office** within 30 days of receipt of results and no later than 10 days after the end of the reporting period.

FOR DEP/DWS USE ONLY: PLEASE INITIAL AND DATE AS COMPLETED

Accepted:	Disapproved:	Data entered into WQTS:
Comments:		